

Memo. on Lincoln Graded School

The Lincoln Graded School was built in 1879 or earlier and is 47 or more years old. The building was abandoned in 1909 with the idea of selling same but was remodeled about 5, 6 or 7 years later and has been used continuously since for the elementary school.

The lot contains $\frac{1}{4}$ acre only whereas 2 acres as a minimum is required for a standard elementary school.

The building is heated by stoves and ventilated through flues without sufficient capacity.

There are no interior toilets.

(Other defects shown on next two sheets)

We are now receiving \$300 annual state subsidy for this school as a standard elementary school but a good many defects are being overlooked by temporarily by the State officials.